

MALONE CAMPBELL ROAD FACILITY, TEXAS CITY, GALVESTON COUNTY, TEXAS

Week ending 10/11/2015

On July 6, 2015 FOSC Zehner initiated an emergency pump down of contaminated storm at the facility which was authorized by the R6 Superfund Division Director. The initiation of emergency actions were necessary to abate the imminent and substantial threat of discharge of several hundred thousand gallons of contaminated storm water located on the Site from several multi-inch rainfalls associated with storm events that had impacted the Site. On-site disposal well WDW-138 began operations on July 6, 2015. The FOSC also authorized the operation of the additional on-site injection well WDW-73. Both injection wells (WDW-138 and WDW-73) are operational, but do have mechanical issues every week, which prevents the wells from injecting at maximum volumes (electrical issues damaged the 150 HP motor on WDW-138 this reporting period, well down for 3-days). Both wells received a total of 260,392 gallons of injectate from October 5 through October 9, for a total injected since emergency response began of 4,462,706 gallons.

Warren Zehner 214-789-1584, David Abshire 214-665-7188